


## SOUTH DAKOTA WATER WELL COMPLETION REPORT

11-02

Location NW 1/4 NE 1/4 Sec 19 Twp 128N Rg 52WCounty Roberts

Please mark well location with an "X"



Well Completion Date

10-12-20

1 Mile

Distance to nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)?

NONE ft. from \_\_\_\_\_ (identify source)

## PROPOSED USE:

☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Test holes  
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

## METHOD OF DRILLING:

Mud Rotary

## CASING DATA:

☐ Steel ☒ Plastic ☐ Other

If other describe \_\_\_\_\_

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
<u>200</u> LB/FT	<u>5</u> IN	<u>0</u> FT	<u>97</u> FT	<u>7 7/8</u> IN
<u>250</u> LB/FT	<u>5</u> IN	<u>97</u> FT	<u>117</u> FT	<u>7 7/8</u> IN
LB/FT	IN	FT	FT	IN

## GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
<u>#20</u>	<u>5</u>	Lb/gal	<u>0</u> Ft	<u>95</u> Ft
		Lb/gal	Ft	Ft

Describe grouting procedure

Tremie Pipe

## SCREEN:

☐ Perforated pipe ☒ Manufactured
Diameter 5 Inches Length 20 FeetMaterial PVCSlot Size 1025 Set From 97 Feet to 117 Feet

Other information \_\_\_\_\_

## WAS A PACKER OR SEAL USED?

☒ Yes ☐ No

If so, what material?

Enviro Plug

Describe packer(s) and location

above Screen

## DISINFECTION: Was well disinfected upon completion?

☒ Yes, How?
Chlorine
☐ No, Why Not?

Lab to which water quality sample sent for analysis

Well Owner: Ducks UnlimitedBusiness Name: Randy Meidenger

Address: \_\_\_\_\_

City, State, Zip: \_\_\_\_\_

## WELL LOG:

FORMATION	DEPTH	
	FROM	TO
<u>Top Soil</u>	<u>0</u>	<u>1</u>
<u>yellow Clay</u>	<u>1</u>	<u>21</u>
<u>Blue Clay</u>	<u>21</u>	<u>95</u>
<u>Sand &amp; Gravel</u>	<u>95</u>	<u>105</u>
<u>Coarse Gravel</u>	<u>105</u>	<u>117</u>

## STATIC WATER LEVEL

25

FEET

If flowing: closed in pressure

PSI

GPM flow \_\_\_\_\_ through \_\_\_\_\_

Inch pipe

Controlled by ☐ Valve ☐ Reducers ☐ Other \_\_\_\_\_

Reduced flow rate \_\_\_\_\_

GPM

Can well be completely shut in?

## WELL TEST DATA:

☒ Pumped Describe: Air
☐ Bailed

☐ Other

Pumping Level Below Land Surface

25 Ft. After 4 Hrs. pumped 50 GPM

\_\_\_\_\_ Ft. After \_\_\_\_\_ Hrs. pumped \_\_\_\_\_ GPM

If pump installed, pump rate: \_\_\_\_\_ GPM

## REMARKS

This well was drilled under license # 722 and this report is true and accurate.Drilling firm: Stretch's Well Service Inc

Signature of License Representative:

Tom Buehler

Signature of Well Owner or Equitable Property Holder:

Randy MeidengerDate: 10-18-2020